

Vestavia Hills Duct Leakage Chart ~ N1103.2.2 ---- Courtesy of AlaGBS.com (256) 352-7235

SF	Max	CFM	SF	Max	CFM	SF	Max	CFM	SF	Max	CFM	SF	Max	CFM	SF	Max	CFM	SF	Max	CFM	SF	Max	CFM	
5000	12%	600	5000	8%	400	5000	6%	300	5000	4%	200	3000	12%	360	3000	8%	240	3000	6%	180	3000	4%	120	
4950	12%	594	4950	8%	396	4950	6%	297	4950	4%	198	2950	12%	354	2950	8%	236	2950	6%	177	2950	4%	118	
4900	12%	588	4900	8%	392	4900	6%	294	4900	4%	196	2900	12%	348	2900	8%	232	2900	6%	174	2900	4%	116	
4850	12%	582	4850	8%	388	4850	6%	291	4850	4%	194	2850	12%	342	2850	8%	228	2850	6%	171	2850	4%	114	
4800	12%	576	4800	8%	384	4800	6%	288	4800	4%	192	2800	12%	336	2800	8%	224	2800	6%	168	2800	4%	112	
4750	12%	570	4750	8%	380	4750	6%	285	4750	4%	190	2750	12%	330	2750	8%	220	2750	6%	165	2750	4%	110	
4700	12%	564	4700	8%	376	4700	6%	282	4700	4%	188	2700	12%	324	2700	8%	216	2700	6%	162	2700	4%	108	
4650	12%	558	4650	8%	372	4650	6%	279	4650	4%	186	2650	12%	318	2650	8%	212	2650	6%	159	2650	4%	106	
4600	12%	552	4600	8%	368	4600	6%	276	4600	4%	184	2600	12%	312	2600	8%	208	2600	6%	156	2600	4%	104	
4550	12%	546	4550	8%	364	4550	6%	273	4550	4%	182	2550	12%	306	2550	8%	204	2550	6%	153	2550	4%	102	
4500	12%	540	4500	8%	360	4500	6%	270	4500	4%	180	2500	12%	300	2500	8%	200	2500	6%	150	2500	4%	100	
4450	12%	534	4450	8%	356	4450	6%	267	4450	4%	178	2450	12%	294	2450	8%	196	2450	6%	147	2450	4%	98	
4400	12%	528	4400	8%	352	4400	6%	264	4400	4%	176	2400	12%	288	2400	8%	192	2400	6%	144	2400	4%	96	
4350	12%	522	4350	8%	348	4350	6%	261	4350	4%	174	2350	12%	282	2350	8%	188	2350	6%	141	2350	4%	94	
4300	12%	516	4300	8%	344	4300	6%	258	4300	4%	172	2300	12%	276	2300	8%	184	2300	6%	138	2300	4%	92	
4250	12%	510	4250	8%	340	4250	6%	255	4250	4%	170	2250	12%	270	2250	8%	180	2250	6%	135	2250	4%	90	
4200	12%	504	4200	8%	336	4200	6%	252	4200	4%	168	2200	12%	264	2200	8%	176	2200	6%	132	2200	4%	88	
4150	12%	498	4150	8%	332	4150	6%	249	4150	4%	166	2150	12%	258	2150	8%	172	2150	6%	129	2150	4%	86	
4100	12%	492	4100	8%	328	4100	6%	246	4100	4%	164	2100	12%	252	2100	8%	168	2100	6%	126	2100	4%	84	
4050	12%	486	4050	8%	324	4050	6%	243	4050	4%	162	2050	12%	246	2050	8%	164	2050	6%	123	2050	4%	82	
4000	12%	480	4000	8%	320	4000	6%	240	4000	4%	160	2000	12%	240	2000	8%	160	2000	6%	120	2000	4%	80	
3950	12%	474	3950	8%	316	3950	6%	237	3950	4%	158	1950	12%	234	1950	8%	156	1950	6%	117	1950	4%	78	
3900	12%	468	3900	8%	312	3900	6%	234	3900	4%	156	1900	12%	228	1900	8%	152	1900	6%	114	1900	4%	76	
3850	12%	462	3850	8%	308	3850	6%	231	3850	4%	154	1850	12%	222	1850	8%	148	1850	6%	111	1850	4%	74	
3800	12%	456	3800	8%	304	3800	6%	228	3800	4%	152	1800	12%	216	1800	8%	144	1800	6%	108	1800	4%	72	
3750	12%	450	3750	8%	300	3750	6%	225	3750	4%	150	1750	12%	210	1750	8%	140	1750	6%	105	1750	4%	70	
3700	12%	444	3700	8%	296	3700	6%	222	3700	4%	148	1700	12%	204	1700	8%	136	1700	6%	102	1700	4%	68	
3650	12%	438	3650	8%	292	3650	6%	219	3650	4%	146	1650	12%	198	1650	8%	132	1650	6%	99	1650	4%	66	
3600	12%	432	3600	8%	288	3600	6%	216	3600	4%	144	1600	12%	192	1600	8%	128	1600	6%	96	1600	4%	64	
3550	12%	426	3550	8%	284	3550	6%	213	3550	4%	142	1550	12%	186	1550	8%	124	1550	6%	93	1550	4%	62	
3500	12%	420	3500	8%	280	3500	6%	210	3500	4%	140	1500	12%	180	1500	8%	120	1500	6%	90	1500	4%	60	
3450	12%	414	3450	8%	276	3450	6%	207	3450	4%	138	1450	12%	174	1450	8%	116	1450	6%	87	1450	4%	58	
3400	12%	408	3400	8%	272	3400	6%	204	3400	4%	136	1400	12%	168	1400	8%	112	1400	6%	84	1400	4%	56	
3350	12%	402	3350	8%	268	3350	6%	201	3350	4%	134	1350	12%	162	1350	8%	108	1350	6%	81	1350	4%	54	
3300	12%	396	3300	8%	264	3300	6%	198	3300	4%	132	1300	12%	156	1300	8%	104	1300	6%	78	1300	4%	52	
3250	12%	390	3250	8%	260	3250	6%	195	3250	4%	130	1250	12%	150	1250	8%	100	1250	6%	75	1250	4%	50	
3200	12%	384	3200	8%	256	3200	6%	192	3200	4%	128	1200	12%	144	1200	8%	96	1200	6%	72	1200	4%	48	
3150	12%	378	3150	8%	252	3150	6%	189	3150	4%	126													
3100	12%	372	3100	8%	248	3100	6%	186	3100	4%	124													
3050	12%	366	3050	8%	244	3050	6%	183	3050	4%	122													

Post Construction Test - Total Leakage < 12% or Outdoors @ < 8%
 Rough In Test - Total Leakage < 6% /// 4% if air handler not installed